


NOTES:

- 1. MAXIMUM AMBIENT TEMPERATURE 50°C
- 2. VENTILATION MUST BE PROVIDED WHEN USED IN AN ENCLOSURE.
- ++ LINE TO LINE VOLTAGE
- F IF GANGED UNITS ARE USED IN A SYSTEM THAT ORDINARILY HAS A COMMON NEUTRAL OR GROUND BETWEEN SOURCE AND LOAD, THE NEUTRAL OR GROUND MUST BE CONNECTED TO THE COMMON TERMINALS OF THE VARIABLE TRANSFORMER ASSEMBLY. IF THE SYSTEM HAS NO NEUTRAL, THE LOAD MUST BE BALANCED OR THE TRANSFORMERS WILL BE DAMAGED.
- JUMPER PROVIDED IN THE STANDARD COMMON POSITION AND SHOULD BE MOVED OR REMOVED AS REQUIRED.

7 (1	VD 011	OCLD	DL IVIC	, v L D	011	\LIVIO V		10 1	(LQO	11 \ _	υ,		
					SPE	CIFICATI	ONS						
	INPUT		OUTPU ⁻			-		SHAFT		TERMINAL CONNECTIONS			
WIRING	VOLTS	HERTZ	VOLTS	CONSTANT CURRENT LOAD		CONSTANT IMPEDANC LOAD		ROTATION TO INCREASE		VOLTAGE AS VIEWED			
				MAX. AMPS	MAX. KVA	MAX. AMPS	MAX. KVA	VOLTAGE					OUTPUT
SINGLE PHASE SERIES	240	50/60	0-240	1.75	0.42	2.2	0.53	CV				1-1 2-2	3-3 3-3
		60	0-264	1.75	0.46	_	_	CV	V 4-		4	1 - 1	3-3
THREE PHASE OPEN DELTA 17	120	50/60	0-120	1.75	0.36	2.2	0.46	CV CC		2-1 1-2		1-1 2-2	3-1-3 3-2-3
		60	0-132	1.75	0.40	_	_	CV	٧	4-1	-4	1-1	3-1-3
UNLESS OTHERWISE SPECIFIED. TOLERANCE IS ± DECIMALS HOLES ANGLES DRAFT .XX about .06 .002 1° 1-1/2° IN [mm] .XXX .005			SPEC. CONTROL DRAWING								CO		
MATERIAL: ALL DIMENSIONS APPLY AFTER PLATING				VARIABLE TRANS TYPE: 171				SFORMER -2					IGY s co.
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO. which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.				TIM RAU		6/5/02		SCALE		DWG.			
						DATE	4.25	LBS. 1=1	CAGE CODE 83008		DWG. SIZE	031 —	-0113



.25 [6.4] WIDE X .03 [0.8] THICK QUICK CONNECT TERMINALS WITH

SOLDER LUGS AT OPPOSITE ENDS

FUSE RECOMMENDED BUT NOT SUPPLIED